

6 White Dove Ct. Lakewood NJ 08701 Tel- (732)668-9078 Fax – (732)358-0168 Cert # 00407A Cert # 00430E Asb # 01200

05/19/2023

Re: 295 Barclay St Perth Amboy NJ 08861

To whom it may concern,

We have sampled the drinking water at the above property for lead. Please note the Federal Action for Copper is 1,300 ug/l (ppb) and for lead is 15 ug/l (ppb).

All results were found to be below the action level.

Feel Free to contact us with any questions.

Matitia Charbit 732-668-9078



30105 Beverly Road Romulus, MI 48174

Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client: AAA Lead Professionals AAT Project: 913938

6 White Dove Court Sampling Date: 05/15/2023 Lakewood, NJ 08701 Date Received: 05/17/2023

 Attn :
 Joseph Perlstein
 Email : joe@aaaleadpro.com
 Date Analyzed : 05/18/2023

 Phone :
 732-668-9078
 Fax :
 Date Reported : 05/19/2023

Client Project: 295 BARCLAY ST PERTH AMB Collected By: MATITIA CHARBIT WSSN:

Project Location: 295 BARCLAY ST PERTH AMBOY NJ

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
8441421	1	CAFETERIA IMMEDIATE	NA		<0.0020	0.0020	Below
8441422	2	CAFETERIA AFTER RUN	NA		<0.0020	0.0020	Below
8441423	3	BOYS BATHRM IMMEDIATE	NA		<0.0020	0.0020	Below
8441424	4	BOYS BATHRM AFTER RUN	NA		<0.0020	0.0020	Below

Analyst Signature

Joseph Kenwabikise

John Stare

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 05/19/2023 AAT Project: 913938



30105 Beverly Road Romulus, MI 48174

Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Copper In Drinking Water by EPA Method 200.5

Client: AAA Lead Professionals AAT Project: 913938

6 White Dove Court Sampling Date : 05/15/2023 Lakewood, NJ 08701 Date Received : 05/17/2023

 Attn :
 Joseph Perlstein
 Email : joe@aaaleadpro.com
 Date Analyzed : 05/18/2023

 Phone :
 732-668-9078
 Fax :
 Date Reported : 05/19/2023

Client Project: 295 BARCLAY ST PERTH AMBOY Collected By: MATITIA CHARBIT WSSN:

Project Location: 295 BARCLAY ST PERTH AMBOY NJ

Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper mg/L (ppm)	Cu Threshold
8441421	1	CAFETERIA IMMEDIATE	NA		0.0731	Below
8441422	2	CAFETERIA AFTER RUN	NA		0.0191	Below
8441423	3	BOYS BATHRM IMMEDIATE	NA		0.0050	Below
8441424	4	BOYS BATHRM AFTER RUN	NA		0.0102	Below

Analyst Signature

Joseph Kenwabikise

John Jane

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results

relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.

NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 05/19/2023 AAT Project: 913938





30105 Beverly Road Romulus, MI 48174

Ph: 734-629-8161; Fax: 734-629-8431

To: AAA Lead Professionals

6 White Dove Court Lakewood, NJ 08701

Attn: Joseph Perlstein Email: joe@aaaleadpro.com

Phone: 732-668-9078

Project Location: 295 BARCLAY ST PERTH AMBOY NJ

AAT Project: 913938

Client Project: 295 BARCLAY ST PERTH AMBO

Date Reported: 05/19/2023

Sample	Client Code	Analysis Requested	Completed	Analyst
8441421	1	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise
8441422	2	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise
8441423	3	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise
8441424	4	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise

Reviewed By

Elyse Bidle

Elype B Me

Quality Assurance Coordinator

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.



AAA LEAD PROFESSIONALS 6 WHITE DOVE CT LAKEWOOD NJ 08701 732-668-9078

SAME	24 HR	48 HR	72 HR
DAY	TAT	TAT	TAT
			<

CHAIN OF CUSTODY

ADDRESS: 295 BARCLAY ST PERTH AMBOY NJ

LEAD AND COPPER IN WATER

SULILEI

SAMPLE	ROOM	PLACE	AREA	
1	CAFETERIA	IMMEDIATE		
2	7.0	AFTER RUN		
3	BOYS BATHROOM	IMMEDIATE		
4	, 1	AFTER RUN		

TAKEN AND RELINQUISHED BY:

MATITIA CHARBIT

DATE: 5/15/23

Signature

3192-913938 Dm 5-17 10a