



6 White Dove Ct. Lakewood NJ 08701
Tel- (732)668-9078 Fax – (732)358-0168
Cert # 00407A Cert # 00430E
Asb # 01200

07/11/2022

Re: 612 Amboy Avenue, Perth Amboy, NJ, 08861

To whom it may concern,

We have sampled the drinking water at the above property for lead and copper. Please note the Federal Action for lead is 15 ug/l (ppb) and for copper is 1,300 ug/l (ppb).

All results were found to be below the action level

Feel Free to contact us with any questions.

A. Kinsbursky

Ariel Kinsbursky
732-668-9078



30105 Beverly Road
 Romulus, MI 48174
 Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : AAA Lead Professionals
 6 White Dove Court
 Lakewood, NJ 08701

Attn : Joseph Perlstein **Email :** joe@aaaleadpro.com
Phone : 732-668-9078 **Fax :**

AAT Project : 814359
Sampling Date : 07/03/2022
Date Received : 07/07/2022
Date Analyzed : 07/07/2022
Date Reported : 07/11/2022

Client Project : 612 AMBOY AVE PERTH AMBOY **Collected By :**
Project Location : 612 AMBOY AVE PERTH AMBOY NJ

WSSN :


Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
7558225	612-1	NURSE RM	DRINKING		0.0039	0.0010	Below
7558226	612-2	NURSE RM	DRINKING		<0.0010	0.0010	Below
7558227	612-3	CAFETERIA BOYS BATHRM	DRINKING		0.0014	0.0010	Below
7558228	612-4	CAFETERIA BOYS BATHRM	DRINKING		<0.0010	0.0010	Below
7558229	612-5	KITCHEN	DRINKING		0.0024	0.0010	Below
7558230	612-6	KITCHEN	DRINKING		<0.0010	0.0010	Below
7558231	612-7	TEACHERS LUNCH RM	DRINKING		0.0020	0.0010	Below
7558232	612-8	TEACHERS LUNCH RM	DRINKING		<0.0010	0.0010	Below
7558233	612-9	FOUNTAIN RECTORY BLDG	DRINKING		<0.0010	0.0010	Below
7558234	612-10	FOUNTAIN RECTORY BLDG	DRINKING		<0.0010	0.0010	Below
7558235	612-13	BSMNT BATHRM	DRINKING		<0.0010	0.0010	Below
7558236	612-14	BSMNT BATHRM	DRINKING		<0.0010	0.0010	Below
7558237	612-15	FOUNTAIN	DRINKING		0.0024	0.0010	Below
7558238	612-16	FOUNTAIN	DRINKING		0.0011	0.0010	Below

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.001 mg/L (ppm) and for Cu is 0.0015 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
-----------	-------------	--------------------	---------	-----------------	-------------------------	-----------------	--------------

Analyst Signature


Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.001 mg/L (ppm) and for Cu is 0.0015 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



Certificate of Analysis: Copper In Drinking Water by EPA Method 200.5

Client : AAA Lead Professionals
 6 White Dove Court
 Lakewood, NJ 08701

Attn : Joseph Perlstein **Email :** joe@aaaleadpro.com
Phone : 732-668-9078 **Fax :**

AAT Project : 814359
Sampling Date : 07/03/2022
Date Received : 07/07/2022
Date Analyzed : 07/08/2022
Date Reported : 07/11/2022

Client Project : 612 AMBOY AVE PERTH AMBOY | **Collected By :**
Project Location : 612 AMBOY AVE PERTH AMBOY NJ

WSSN :


Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper mg/L (ppm)	Cu Threshold
7558225	612-1	NURSE RM	DRINKING		0.0563	Below
7558226	612-2	NURSE RM	DRINKING		0.0166	Below
7558227	612-3	CAFETERIA BOYS BATHRM	DRINKING		0.0238	Below
7558228	612-4	CAFETERIA BOYS BATHRM	DRINKING		0.0232	Below
7558229	612-5	KITCHEN	DRINKING		0.0194	Below
7558230	612-6	KITCHEN	DRINKING		0.0144	Below
7558231	612-7	TEACHERS LUNCH RM	DRINKING		0.0994	Below
7558232	612-8	TEACHERS LUNCH RM	DRINKING		0.0268	Below
7558233	612-9	FOUNTAIN RECTORY BLDG	DRINKING		0.2916	Below
7558234	612-10	FOUNTAIN RECTORY BLDG	DRINKING		0.2107	Below
7558235	612-13	BSMNT BATHRM	DRINKING		0.1876	Below
7558236	612-14	BSMNT BATHRM	DRINKING		0.0513	Below
7558237	612-15	FOUNTAIN	DRINKING		0.0026	Below
7558238	612-16	FOUNTAIN	DRINKING		0.0023	Below

Analyst Signature



Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.001 mg/L (ppm) and for Cu is 0.0015 mg/L (ppm).
 For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.
 EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu
 The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

To : AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

AAT Project : 814359
Client Project : 612 AMBOY AVE PERTH AMBC
Date Reported : 07/11/2022

Attn : Joseph Perlstein Email : joe@aaaleadpro.com
Phone : 732-668-9078

Project Location : 612 AMBOY AVE PERTH AMBOY NJ

Sample	Client Code	Analysis Requested	Completed	Analyst
7558225	612-1	Pb/Cu in Drinking Water	07/07/2022	Joseph Kenwabikise
7558226	612-2	Pb/Cu in Drinking Water	07/07/2022	Joseph Kenwabikise
7558227	612-3	Pb/Cu in Drinking Water	07/07/2022	Joseph Kenwabikise
7558228	612-4	Pb/Cu in Drinking Water	07/07/2022	Joseph Kenwabikise
7558229	612-5	Pb/Cu in Drinking Water	07/07/2022	Joseph Kenwabikise
7558230	612-6	Pb/Cu in Drinking Water	07/07/2022	Joseph Kenwabikise
7558231	612-7	Pb/Cu in Drinking Water	07/07/2022	Joseph Kenwabikise
7558232	612-8	Pb/Cu in Drinking Water	07/07/2022	Joseph Kenwabikise
7558233	612-9	Pb/Cu in Drinking Water	07/07/2022	Joseph Kenwabikise
7558234	612-10	Pb/Cu in Drinking Water	07/07/2022	Joseph Kenwabikise
7558235	612-13	Pb/Cu in Drinking Water	07/07/2022	Joseph Kenwabikise
7558236	612-14	Pb/Cu in Drinking Water	07/07/2022	Joseph Kenwabikise
7558237	612-15	Pb/Cu in Drinking Water	07/07/2022	Joseph Kenwabikise
7558238	612-16	Pb/Cu in Drinking Water	07/07/2022	Joseph Kenwabikise

Reviewed By

Quality Assurance Coordinator - Stephen Northcott

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.

NY State DOH ELAP -Lab ID #11864, Michigan State Lab # 9996

Date Printed: 07/11/2022 4:16AM

AAT Project: 814359

